



PSB Singapore

CERTIFICATE OF CONFORMITY

No. CLSAN 080455 0006 Rev. 00

Initial No. CLS1A 16 08 80455 003

Certificate Holder:

Tonn Cable Sdn. Bhd.

Lot 1 (PT 54)

Jalan Perusahaan 5 , Kawasan Perumahan Beranang

43700 Beranang Selangor

MALAYSIA

Certification Mark:



TÜV SÜD PSB

Product:

PVC Insulated Non-sheath cables

Brand Name:

TONN CABLE

Model(s):

CU/PVC

Product Details:

Voltage : 450/750V

Conductor : Stranded plain annealed copper

Insulation : PVC

Sizes : 1C x 1.5mm² to 1C x 400mm²

Standard(s):

SS 358-3:1996/A1:1998

Country of Origin:

Malaysia

Test Report(s):

7191131651-EEC16/02--01

7191131651-EEC16/02--02

7191131651-EEC16/02--03

7191131651-EEC16/02--04

Valid until:

2024-08-02

Products listed under Class 1A must have TÜV SÜD PSB PLS mark as shown above affixed/printed on them. Failure to comply with this requirement may result in revocation of this certificate.

Page 1 of 1

Issued on: 2019-07-25

Vice-President (Certification Department)

TÜV SÜD PSB

This Certificate is part of a full Report and should be read in conjunction with it. This Certificate remains the property of TÜV SÜD PSB Pte Ltd and shall be returned upon request. The use of this Certificate is subjected to TÜV SÜD Group Testing and Certification Regulations; TÜV SÜD PSB Pte Ltd (PSB) General Terms and Conditions of Business and PSB Product Listing Scheme (PLS) Application Fact Sheet. The manufacturer is solely responsible for compliance of any product that has the same designation as the product type-tested. Persons relying on this Certificate should verify its validity by checking TÜV SÜD PSB's website at www.tuv.sud-psb.sg

TÜV SÜD PSB Pte Ltd • 1 Science Park Drive • Singapore 118221

ZERTIFIKAT ♦ CERTIFICATE ♦ 認證證書 ♦ CERTIFICADO ♦ CERTIFICAT